

**Henry P. Roybal**  
*Commissioner, District 1*

**Miguel M. Chavez**  
*Commissioner, District 2*

**Robert A. Anaya**  
*Commissioner, District 3*



**Kathy Holian**  
*Commissioner, District 4*

**Elizabeth Stefanics**  
*Commissioner, District 5*

**Katherine Miller**  
*County Manager*

June 8, 2016

**SANTA FE COUNTY**  
**GENERATOR INSTALLATION AT THE RANCHO VIEJO FIRE STATION**

**IFB #2016-0335-FD/IC**

**ADDENDUM #1**

Dear Bidders,

This addendum is issued to reflect the following immediately. It shall be the responsibility of interested bidder to adhere to any changes or revisions to the IFB as identified in this Addendum No. 1. This documentation shall become permanent and made part of the departmental files.

---

*Please see changes below to Specifications as well as to Drawings*

---

**CHANGES TO SPECIFICATIONS**

Division 16622 – Emergency/Standby Power System Generator Set

1. Delete paragraph 1.03 ACCEPTABLE MANUFACTURERS
2. Add new Paragraph 1.03 ACCEPTABLE MANUFACTURERS as follows:
  - 1.03 Acceptable Manufacturers
    1. Cummins Power Generation
    2. Caterpillar
    3. Or Products equal to equipment specified

## **CHANGES TO DRAWINGS**

### Sheet E-000 Title Sheet

1. Revise General Note #6 as follows:
  
6. All raceway shall be run concealed unless otherwise noted below:
  - A. Exposed conduit shall be allowed on conduit racks installed above structure at high ceiling of apparatus bay. Paint conduit to match existing.
  - B. Exposed conduit may be installed in mechanical loft area.
  - C. Exposed conduit may be installed in electrical room.
  - D. Under no circumstances will exposed conduit be allowed on interior finished walls including apparatus bay vertical walls.

---

Please add this Addendum #1 to the original bid documents and refer to bid documents, hereto as such. This and all subsequent addenda will become part of any resulting contract documents and have effects as if original issued. All other unaffected sections will have their original interpretation and remain in full force and effect.

Proponents are reminded that any questions or need for clarification must be addressed to Iris Cordova, Senior Procurement Specialist at [icordova@santafecountynm.gov](mailto:icordova@santafecountynm.gov).