



WATER QUALITY
CONSTRUCTION



Preliminary Engineering Report


Wastewater Facilities for
Communities of Sombrillo & Arroyo Seco
Santa Fe County, New Mexico

February 2009




Souder, Miller & Associates
3451 Candelaria Road N.E.
Albuquerque, NM 87107
(505)299-0942

- Souder, Miller & Associates
 - Jerry May, P.E.
 - Lam Ho, E.I.T.
 - Judy Holland
- Santa Fe County
 - James Lujan
 - Doug Sayre, P.E.
- NMED CPB
 - Chris Vick, P.E.



Preliminary Engineering Report for Wastewater Facilities

- Standard format as per USDA Rural Utilities Services (RUS) Bulletin 1780-3
- Scope of Services by Santa Fe County
- SMA responded to County RFP on February 14, 2008
- SMA conducted site inspections and study in Summer of 2008




Preliminary Engineering Report Outline

- Project Planning Area
- Existing Facilities
- Need for Project
- Alternatives Considered
- Selection of an Alternative
- Proposed Project
- Conclusions and Recommendations




Project Planning Area




Project Planning Area

- Environmental Resources Present
 - Significant areas of high quality farmland
 - Wetlands in vicinity of Santa Cruz River
 - Rangeland surrounding area managed by BLM
 - Floodplains in area of Santa Cruz River and Arroyo Seco



Project Planning Area

- Environmental Resources Present (cont)
 - No historical registered sites located in project area
 - Endangered species present in Santa Fe County, but should not be affected by proposed project
 - Population growth estimated from 2,960 in 2008 to 5,024 in 2028.



Existing Facilities

- No community wastewater facilities, septic tanks are utilized
- Estimated wastewater flows
(residential and commercial)
 - 2008 – 101,909 gpd
 - 2028 – 172,953 gpd



Need for Project

- Depth to groundwater in study area ranges from 6 ft. to 100 ft. below grade
- High potential for nitrate from septic tank leachfields to impact groundwater
(drinking water standard for nitrate is 10 ppm)
- Projected growth in next 20 years could result more than 800 additional septic tanks in the area
- Current NMED regulations require a minimum of 0.75 acre plus for a septic tank




Wastewater Alternatives Considered

- Collection Systems
 - No action
 - Conventional gravity/force main system
 - Septic tank effluent pressure (STEP) and septic tank effluent gravity (STEG) system
- Vacuum system



STEP/STEG Collection System



PROJECT: STEP/STEG COLLECTION SYSTEM
 LOCATION: VALLEY OF ARROYO SECS
 COUNTY: SANTA FE COUNTY, NEW MEXICO


DRAWN BY: [Name]
 CHECKED BY: [Name]
 DATE: [Date]

ASMA
 1511 COLUMBIAN BLVD. SUITE 2
 ALBUQUERQUE, NEW MEXICO 87104
 (505) 263-0000 / (505) 263-0001

Figure 0

Vacuum Collection System

- Best utilized in low lying areas with existing conditions, such as high groundwater, bedrock, sensitive ecosystems, that limit other technologies
- High capital & operating cost system
- Not good technology for project area and not considered for further study



Wastewater Treatment Alternatives

- No Action – Septic Tanks
- Advanced Treatment Units (ATU)
- Connection to existing wastewater treatment plants
- Centralized wastewater treatment facility
- Individual community wastewater treatment facility



Advanced Treatment Units

- Upgrade or replacement of septic tanks and individual properties
- 20 vendors approved by NMED
- Requires periodic maintenance
- Electrical cost
- Provides effluent quality similar to municipal WWTP – nitrate < 20 ppm



Connection to Existing WWTP's

- Connection to City of Española Collection System
 - Adding community flow can be accommodated
 - Easement with Pueblo of Santa Clara required for closest connection
 - Possible routing across Santa Cruz River and down State Highway



Connection to Existing WWTP's

- Connection to Santa Clara Development Corporation's WWTP
 - Not in operation, can accommodate flows for a number of years (80,000 gal/capacity)
 - Expandable to accommodate future flows
 - Routing across US Highway 84




Centralized or Individual WWTP's

- Sequencing Batch Reactor – (SBR)
- Integrated Fixed Film Inactivated Sludge (IFAS)
- Membrane Bioreactor (MBR)
- All capable of producing Class IA or Class IB reclaimed wastewater for reuse



Centralized or Individual WWTP's



Wastewater Treatment Type Selection

Parameter	Score			
	SBR	Aerotor	MBR	ATU
Construction Cost	1	3	1	4
Operational Cost	1	3	2	4
Biosolids Generation	3	3	4	2
Operational Complexity	1	2	3	4
Effluent Quality	4	3	4	3
Odors	4	4	4	4
Land Required	1	3	2	4
Total	15	21	20	25



WWTP Effluent Disposal Alternatives

- Surface disposal to Santa Cruz River or Arroyo Seco
- Surface disposal by irrigation
- Subsurface disposal by aquifer injection
- Subsurface disposal by infiltration



WWTP Biosolids Processing and Disposal

- Biosolids (sludge) produced by WWTP's must be permitted, processed and disposed by NMED permit in accordance with EPA regulations
- Biosolids may be landfilled (closest permitted landfill is Rio Rancho) or reused
- Biosolids may also be transported and processed at large scale WWTP such as Española




Selection of an Alternative

Collection System

Alternatives	Construction Cost	Non-Construction Cost	Total Cost
Conventional Gravity/Force Main Sewer	\$9,376,828	\$2,520,098	\$11,896,926
STEP/STEG System	\$7,460,978	\$1,895,824	\$ 9,356,802

Criteria	Conventional Gravity/Force Main	Low pressure STEP/STEG
Ease of design	5	3
Capital cost	3	5
Construction depth	3	5
High groundwater impact	3	5
Infiltration potential	3	5
Traffic control	3	3
Community disruption	3	3
Easement/Access	3	3
Expandability	5	3
O&M	4	3
Capital cost	3	4
Total Score	38	42



Treatment System Alternative Selection

Criteria	Connection to SDC WWTP	Connection to Española WWTP	Single Centralized Treatment System	Individual Community Treatment Systems
Additional Collection System Cost	3	2	4	5
Ease of Design	5	5	3	3
Capital Cost	5	4	2	1
O&M Cost	5	5	2	2
Ease of Operation	5	5	2	1
Footprint	5	5	2	1
Effluent Quality (Reuse)	1	1	5	5
Biosolids Production	5	5	2	2
Operator Classification	5	5	2	2
Odor	5	5	3	3
Noise	5	5	3	3
Single Responsible Party	5	5	5	4
Required Level of Management	5	5	2	1
User rates	5	4	2	1
Total Score	64	61	38	34




Treatment System Alternative Selection

Alternatives	Construction Cost	Non-Construction Cost	Total Cost
Advanced Treatment Units (High cost)	\$ 11,440,000	\$ 2,288,000	\$ 13,728,000
Connect to the City of Española WWTP	\$ 756,299	\$ 191,533	\$ 947,832
Connect to the SCDC WWTP	\$ 589,834	\$ 149,376	\$ 739,210
Sequencing Batch Reactor	\$ 4,349,316	\$ 1,133,120	\$ 5,482,436
IFAS (STM - Aerotor™)	\$ 737,591	\$ 218,451	\$ 956,042
Membrane Biological Reactor	\$ 4,283,091	\$ 861,618	\$ 5,144,709
Individual Wastewater Treatment Facilities	\$ 1,253,588	\$ 323,802	\$ 1,577,390
Packaged SBR Expansion of SCDC WWTP	\$ 1,587,860	\$ 158,786	\$ 1,746,645



Effluent Disposal Alternative Selection

Criteria	Surface River/Arroyo	Subsurface Aquifer Injection	Surface Irrigation	Subsurface Irrigation
Land Requirements	5	2	1	1
Formal Agreements	3	3	1	1
Reuse of Effluent	1	3	5	5
Year-Round Acceptance	5	4	1	1
Capital Cost	5	1	2	2
Operational Cost	2	2	5	3
Total Score	21	20	18	16



Effluent Disposal Alternative Selection

Alternatives	Construction Cost	Non-Construction Cost	Total Cost
Surface Effluent Disposal (Individual WWTPs)	\$175,365	\$44,411	\$219,776
Surface Effluent Disposal (Centralized WWTP)	\$93,904	\$23,781	\$117,685
Subsurface Effluent Aquifer Injection	\$1,342,225	\$339,918	\$1,682,143
Community Surface Effluent Irrigation	\$342,039	\$86,621	\$428,661
Subsurface Effluent Disposal	\$490,039	\$124,102	\$614,141
Reuse Piping System to Sports Fields	\$47,497	\$12,029	\$59,526
Reuse Piping System to Commercial Site	\$160,181	\$40,566	\$200,746
Reuse Piping System to Elementary School	\$267,432	\$67,727	\$335,159
Reuse Piping System to Golf Course Pond	\$231,217	\$58,556	\$289,773
36 Ac. Reuse Surface Irrigation System	\$477,689	\$95,538	\$573,226



Proposed Project (Recommended Alternatives)

- A proposed phase breakdown for this project is:
 - Phase 1: Sombrillo STEP/STEG wastewater collection system design - \$777,819
 - Phase 2: Sombrillo wastewater collection system construction - \$3,058,850
 - Phase 3: Sombrillo wastewater interconnection to SCDC WWTP - \$589,834
 - Phase 4: SCDC WWTP regional reuse piping system to Black Mesa Golf Course pond design and construction - \$289,772
 - Phase 5: Arroyo Seco wastewater collection system design - \$1,337,929
 - Phase 6: Arroyo Seco wastewater collection system construction - \$4,680,703
 - Phase 7: SCDC WWTP packaged SBR expansion design and construction - \$1,746,645



Questions?

