

Justin S. Greene
Commissioner, District 1

Anna Hansen
Commissioner, District 2

Camilla Bustamante
Commissioner, District 3



Anna T. Hamilton
Commissioner, District 4

Hank Hughes
Commissioner, District 5

Gregory S. Shaffer
County Manager

October 17, 2024

SANTA FE COUNTY
IFB NO. 2025-0120-PW/DK
Turquoise Trail Bulk Water
ADDENDUM NO. 2

Dear Proponents,

This addendum is issued to reflect the following immediately. It shall be the responsibility of interested Bidders to adhere to any changes or revisions to the IFB as identified in this Addendum No. 2. This documentation shall become permanent and made part of the departmental files.

Bid opening date has been extended to Friday, October 25th

Attachment A: Pre-Bid Agenda
Attachment B: Sign-In Sheet

Question No. 1: Would Santa Fe Public Works consider specifying the Rieberlok internally restrained gasket for this project? This gasket is used to internally restrain C-900 PVC pipe eliminating the need for external restraints, which we believe would be a valuable addition to the project.

Answer No. 1: This material substitution is not considered at this time as it is not in line with basis of bid. Rieberlok IR gaskets will be considered when the contract is awarded, if economically feasible to the project and meets design criteria.

Update No. 1: The following bid items should read "...6-ft Depth, CIP.", not "... 6" Depth, CIP."

Item # 17	4" C-900 PVC Waterline Pipe, Excl. Fittings, Incl. Trace Wire, Trench & Compacted Backfill, Up to 6-ft Depth, CIP. Restraining Harnesses are Incidental.
18	12" C-900 PVC Waterline Pipe, Excl. Fittings, Incl. Trace Wire, Trench & Compacted Backfill, Up to 6-ft Depth, CIP. Restraining Harnesses are Incidental.

Update No. 2: Contractor is required to prepare and submit a project specific sealed traffic control plan, along with the Traffic Control Supervisor Certifications, in accordance with NMDOT.

102 Grant Avenue · P.O. Box 276 · Santa Fe, New Mexico 87504-0276 · 505-986-6200 · FAX:
505-995-2740 www.santafecountynm.gov

Contractor shall obtain the required NMDOT Utility Permit and the required Traffic Control/Roadway Work Permit prior to commencing any work within the NMDOT Right of Way. Contractor must also provide the Certificate of Insurance in accordance with NMDOT requirements.

Contractor shall coordinate the following NMDOT District Agent:

Marcos G. Herrera
Utility Permit Agent
NMDOT District 5
Traffic Section
P.O. Box 4127
Santa Fe, NM 87502
Cell: 505-690-1524
Marcos.herrera@dot.nm.gov

Please add this Addendum No. 2 to the original proposal documents and refer to proposal documents, hereto as such. This and all subsequent addenda will become part of any resulting contract documents and have effects as if original issued. All other unaffected sections will have their original interpretation and remain in full force and effect. Responders are reminded that any questions or need for clarification must be addressed to Dani Koussa, Procurement Specialist Senior at dkoussa@santafecountynm.gov.