


Henry P. Roybal
Commissioner, District 1

Anna Hansen
Commissioner, District 2

Robert A. Anaya
Commissioner, District 3



Anna T. Hamilton
Commissioner, District 4

Ed Moreno
Commissioner, District 5

Katherine Miller
County Manager

December 6, 2018

IFB# 2019-00140-PW/CW
Vista Aurora Subdivision Sanitary Sewer Line Construction Project

ADDENDUM #4

*****ADDITIONAL INFORMATION *****

Dear Proponents,

This addendum is issued to reflect the following immediately. It shall be the responsibility of interested Offerors to adhere to any changes or revisions to the IFB as identified in this Addendum No.4. This documentation shall become permanent and made part of the departmental files.

Please note that the Public Works Department and the Purchasing Division for the County have provided additional information relating to the Invitation for Bid # 2019-0140-PW/CW.

• **Question and Response**

1. The pavement replacement detail on plan sheet 1-7 shows 6" of base course but no asphalt thickness, stating, "place asphalt to match existing thickness...". For bidding purposes, we need to know what this thickness is.

Regarding Engineering Design Drawing Sheet 1-7 "Typical saw Cut and Pavement Patch Detail", assume the existing asphalt pavement is 4-inches in thickness and will require the same thickness to be replaced.

Please add this Addendum #3 to the original bid documents and refer to bid documents, hereto as such. This and all subsequent addenda will become part of any resulting contract documents and have effects as if original issued. All other unaffected sections will have their original interpretation and remain in full force and effect. Bidders are reminded that any questions or need for clarification must be addressed to Coralie Whitmore, Senior Procurement Specialist at cgwhitmore@santafecountynm.gov