
N SUMMIT DR
NA
CAMINO DEL OSO
VIA COLIBRIS
PASEO SEGUNDO
MDE PARK RD
PASEO PRIMERO
TEHP04
TEHP03
2042
PASEO IGLESIAS
TEHP05
EL PASEO
2314C
SOUTH SUMMIT DR
EL PASE
TEHP02
NN
2313C
CAMINO LISO
TEHP01
SOUTH SUMMIT DR
CUESTA BRAVA

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** Hyde Park Estates
- **Physical Hydrant Location:** Paseo Primero / la Entrada
- **County GPS Coordinates:** N35°42.917' / W105°53.374' **Hydrant Number:** SDCW 2042
- **Water System Owner:** HPEsbtes
- **Type of System:** Pressurized ☑ Draft ☐ If Draft - Static Pressure: _____
- **Hydrant Make:** Kennedy ☐ Mueller ☐ Other Metropolitan ☑ **Thread Type:** NST ☑ SF ☑
- **Turns To Open Stem Nut:** 16 **Size of Main:** _____
- **Size of Lead:** 6" **Valve in Lead:** Yes ☐ No ☑ none found
- **Lead Valve - Feet From Hydrant:** _____ **Compass Heading:** _____
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☐ No ☐ N/A
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	100				

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☑	☐

Color: Blue ☐ Green ☑ Orange ☐ Red ☐ All Red Draft ☐

- **Comments/Notes** GPS Coord only

Inspected By: BB / BP **Time:** 1600

Hydrant Form / 2-03

02/24/03

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** " " Estates
- **Physical Hydrant Location:** Cam. Lisa / Paseo Primero
- **County GPS Coordinates:** N35°42.636' / W105°53.076' **Hydrant Number:** FEHP01
- **Water System Owner:** AP Estates
- **Type of System:** Pressurized ☐ Draft ☑ If Draft - Static Pressure: 95
- **Hydrant Make:** Kennedy ☐ Mueller ☑ Other ☐ **Thread Type:** NST ☐ SF ☑
- **Turns To Open Stem Nut:** _____ **Size of Main:** _____
- **Size of Lead:** _____ **Valve in Lead:** Yes ☑ No ☐
- **Lead Valve - Feet From Hydrant:** 2' **Compass Heading:** N
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☑ No ☐
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	95				

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☑	☐

Color: Blue ☐ Green ☐ Orange ☐ Red ☒ All Red Draft ☒

- **Comments/Notes** GPS only

Inspected By: BD/BP **Time:** 1605

Hydrant Form / 2-03

02/24/03

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** " " Estates
- **Physical Hydrant Location:** El Paseo / Paseo del Monte
- **County GPS Coordinates:** N35°42.721 / W105°52.948' **Hydrant Number:** TEHP02
- **Water System Owner:** AP Estates
- **Type of System:** Pressurized ☐ Draft ☑ If Draft - Static Pressure: 60
- **Hydrant Make:** Kennedy ☐ Mueller ☑ Other ☐ **Thread Type:** NST ☐ SF ☑
- **Turns To Open Stem Nut:** 18 **Size of Main:** _____
- **Size of Lead:** _____ **Valve in Lead:** Yes ☐ No ☐
- **Lead Valve - Feet From Hydrant:** 4' **Compass Heading:** E by edge of road
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☑ No ☐
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	60				

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☑	☐

Color: Blue ☐ Green ☐ Orange ☐ Red ☒ All Red Draft ☒

- **Comments/Notes** GPS only

Inspected By: BP/BP **Time:** 1607

Hydrant Form / 2-03

02/24/03

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** " " Estates
- **Physical Hydrant Location:** Water Tank -
- **County GPS Coordinates:** N35°42.920/W105°52.928 **Hydrant Number:** TEHP03
- **Water System Owner:** HP Estates
- **Type of System:** Pressurized ☐ Draft ☑ If Draft - Static Pressure: 1
- **Hydrant Make:** Kennedy ☐ Mueller ☑ Other ☐ **Thread Type:** NST ☐ SF ☑
- **Turns To Open Stem Nut:** 16 **Size of Main:** _____
- **Size of Lead:** _____ **Valve in Lead:** Yes ☐ No ☐
- **Lead Valve - Feet From Hydrant:** 1 **Compass Heading:** W
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☑ No ☐
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	1				

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☐	☐

Color: Blue ☐ Green ☐ Orange ☐ Red ☐ All Red Draft ☑

- **Comments/Notes** GPS only

Inspected By: JB/BP **Time:** 1610

Hydrant Form / 2-03

02/24/03

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** " " Estates
- **Physical Hydrant Location:** Paseo del Monte / Paseo Ponderosa
- **County GPS Coordinates:** N35°42.940' / W105°53.071" **Hydrant Number:** TEHP04
- **Water System Owner:** AP Estates
- **Type of System:** Pressurized ☐ Draft ☑ If Draft - Static Pressure: 50
- **Hydrant Make:** Kennedy ☐ Mueller ☑ Other ☐ **Thread Type:** NST ☐ SF ☑
- **Turns To Open Stem Nut:** 17 **Size of Main:** _____
- **Size of Lead:** _____ **Valve in Lead:** Yes ☐ No ☐
- **Lead Valve - Feet From Hydrant:** 2' **Compass Heading:** N
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☑ No ☐
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	50				< 500

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☑	☐

Color: ~~Blue~~ ☐ Green ☐ Orange ☐ Red ☒ ~~All Red-Draft~~ ☒

- **Comments/Notes** GPS coord only

Inspected By: BB/BP **Time:** 1615

Hydrant Form / 2-03

02/24/03

Santa Fe County Fire Department

Hydrant Field Data Collection Form

- **Fire District:** Hyde Park
- **Subdivision:** " " Estates
- **Physical Hydrant Location:** Paseo del Monte/Paseo Sylvian
- **County GPS Coordinates:** N35°42.850'/W105°53.185' **Hydrant Number:** TEHP05
- **Water System Owner:** AP Estates
- **Type of System:** Pressurized ☐ Draft ☑ If Draft - Static Pressure: 100
- **Hydrant Make:** Kennedy ☐ Mueller ☑ Other ☐ **Thread Type:** NST ☐ SE ☑
- **Turns To Open Stem Nut:** 17 **Size of Main:** _____
- **Size of Lead:** _____ **Valve in Lead:** Yes ☐ No ☐
- **Lead Valve - Feet From Hydrant:** 2' **Compass Heading:** W
- **Storage Tank Full:** Yes ☑ No ☐ **Depth Indicator Gauge on Storage:** Yes ☑ No ☐
- **Test Data:**

Date Tested	Static PSI	Residual PSI	Pitot Reading	Outlet Size	GPM
7-15-03	100				
4-19-11	104		15	2.5	650

- **Work Performed:**

	Yes	No		Yes	No
1. Hydrant Flowed	☐	☑	6. Caps In Place/Chains	☑	☐
2. Valve Closes	☑	☐	7. Lubricated	☑	☐
3. Gaskets Checked	☑	☐	8. Brush Cleared	☑	☐
4. Any Leaks Noticed	☐	☑	9. Numbered	☑	☐
5. Drain Valve Functioning	☑	☐	10. Painted	☑	☐

Color: Blue ☐ Green ☐ Orange ☑ Red ☐ All Red Draft ☐

- **Comments/Notes** GPS coord only

Inspected By: B/BP **Time:** 1615

Hydrant Form / 2-03

02/24/03